



Certificate of Product Approval

Licensee:

Bahra Cables Company

CPC Industrial Park, Bahra, 21432, Jeddah, Kingdom of Saudi Arabia

Factory:

CPC Industrial Park, Bahra, 21432, Jeddah, Kingdom of Saudi Arabia

Standard:

IEC 60502-2:2014

Description:

Medium voltage power cables up to 33kV

Details:

Bonded or strippable semi-conducting insulation screen. Copper wire and/or tape screen. ST8 low smoke, zero halogen, extruded outer sheath. Voltage ratings: 3.6/6(7.2)kV, 6/10(12)kV and 8.7/15(17.5)kV. Zero Halogen to IEC 60754 1&2. Low smoke to IEC 61034.

Materials:

Insulation XLPE, Sheath ST 8

Brand Name:

N/A

Origin Mark:

BAHRA CABLES CO. or BAHRA CABLES

Permissible Approval Marks:

BASEC

BASEC name



BASEC roundel

Signed for and on behalf of
BASEC Group Ltd

Date: 08/02/2024

Date of original issue: 27/02/2012

Check BASEC website to verify validity.

Page 1 of 2

BASEC Group Ltd, Presley House, Presley Way, Milton Keynes, MK8 0ES, UK
Registered in England No. 13950143, Tel: +44 (0)1908 267300
Email: mail@basec.org.uk Web: www.basec.org.uk

BSF079 Issue 5 (20-03-2023)



Expiry date:
12/06/2026



Type(s) and Range(s) of Approval

Table / Clause	Code Designation	Conductor Class	Range of Cores	Min Nominal Size -sqmm	Max Nominal Size -sqmm
N/A	N/A	Class 2	1	95	630

Signed for and on behalf of
BASEC Group Ltd

Date: 08/02/2024

Date of original issue: 27/02/2012

Check BASEC website to verify validity.

Page 2 of 2

BASEC Group Ltd, Presley House, Presley Way, Milton Keynes, MK8 0ES, UK
Registered in England No. 13950143, Tel: +44 (0)1908 267300
Email: mail@basec.org.uk Web: www.basec.org.uk

BSF079 Issue 5 (20-03-2023)



Expiry date:
12/06/2026