

Certificate of Product Approval

Licensee:

Bahra Cables Company

CPC Industrial Park, Bahra, 21432, Jeddah, Kingdom of Saudi Arabia

Factory:

CPC Industrial Park, Bahra, 21432, Jeddah, Kingdom of Saudi Arabia

Standard:

BS 7846:2015

Description:

Armoured fire resistant power cables

Details:

Resistance to fire - Category F120.

Materials:

Insulation EI 5, Sheath LTS 1

Brand Name:

N/A

Origin Mark:

BAHRA CABLES CO. OR BAHRA CABLES

Permissible Approval Marks:

BASEC

BASEC name



BASEC roundel

Signed for and on behalf of
BASEC Group Ltd



Date: 12/09/2024

Date of original issue: 12/09/2024

Check BASEC website to verify validity.

Page 1 of 2

BASEC Group Ltd, Presley House, Presley Way, Milton Keynes, MK8 0ES, UK
Registered in England No. 13950143, Tel: +44 (0)1908 267300
Email: mail@basec.org.uk Web: www.basec.org.uk

BSF079 Issue 5 (20-03-2023)



Expiry date:
12/06/2026



Certificate No:
178/001/059
Issue No: 1

Type(s) and Range(s) of Approval

Table / Clause	Code Designation	Conductor Class	Range of Cores	Min Nominal Size -sqmm	Max Nominal Size - sqmm
----------------	------------------	-----------------	----------------	------------------------	-------------------------

7	N/A	Class 2	5	2.5	6

Signed for and on behalf of
BASEC Group Ltd

 Date: 12/09/2024

Date of original issue: 12/09/2024

Check BASEC website to verify validity.

Page 2 of 2



Expiry date:
12/06/2026