

## Certificate of Assessed Design

Licensee:

### **Bahra Cables Company**

CPC Industrial Park, Bahra, 21432, Jeddah, Kingdom of Saudi Arabia

Factory:

CPC Industrial Park, Bahra, 21432, Jeddah, Kingdom of Saudi Arabia

Standard:

CAD048

Description:

Fire Resistant Cables (Cu/MICA/XL-LSHF) 450/750V rated,  
generally manufactured as per BS EN 50525-3-41:2011 Clause no 4.1

Details:

Single Core, 1.5sqmm to 630sqmm, Non-sheathed cables with  
halogen-free crosslinked insulation, and low emission of smoke cables.

Materials:

Insulation LS0H-XL, Sheath N/A

Brand Name:

N/A

Origin Mark:

BASEC CAD048

Permissible Approval Marks:

**BASEC**

BASEC name



BASEC roundel

Signed for and on behalf of  
BASEC Group Ltd

*Kieran O'Brien*

Date: 12/04/2023

Date of original issue: 12/04/2023

Check BASEC website to verify validity.

Page 1 of 1

BASEC Group Ltd, Presley House, Presley Way, Milton Keynes, MK8 0ES, UK

Registered in England No. 13950143, Tel: +44(0)1908267300

Email: [mail@basec.org.uk](mailto:mail@basec.org.uk) Web: [www.basec.org.uk](http://www.basec.org.uk)

BSF126 Issue 002 (20-03-2023)

This certificate is associated with CAD048 Appendix

Expiry date:

12/06/2026