



Certificate of Compliance

Certificate: 2451293

Master Contract: 253425

Project: 2451293

Date Issued: January 10, 2012

Issued to: Bahra Cables Company

CPC Industrial Park

Bahra

Jeddah, 5 21432

SA

Attention: Mohammed Ali

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only.



Kim Nguyen

Issued by: Kim Nguyen, P. Eng.

PRODUCTS

CLASS 5832 03 - WIRES - Thermosetting

CLASS 5832 83 - WIRES - Thermosetting - Certified to US Standards

Thermoset Insulated Wires and Cables, single conductor construction with XLPE insulation, sizes 14 AWG to 2000 kcmil.:

For Class 5832 03:

1. Type RW90, rated 90C wet and dry, 600V, GRIL.
2. Type SIS, rated 90C dry, 600V, GRIL.

For Class 5832 83:

1. Type RHW, rated 75C wet and dry, 600V, GRIL.
2. Type RHW-2, rated 90C wet and dry, 600V, GRIL.
3. Type SIS, rated 90C dry, 600V, GRIL.



Certificate: 2451293

Master Contract: 253425

Project: 2451293

Date Issued: January 10, 2012

APPLICABLE REQUIREMENTS

CSA C22.2 No 38 - Thermoset-Insulated Wires and Cables.

UL 44 - Thermoset-Insulated Wires and Cables.